



RTC Manufacturing, Inc.

P. O. Box 150189
Arlington, TX 76015

(800) 782-8721
(817) 274-3610 fax

Model TR-3 / TR-4
GPS Time Reference

Application Note Number 5

Setup Instructions for the TR-3 / TR-4 GPS Time Reference
for

NAZTEC CONTROLLERS

Model 900 METRO Version 12.3:

Pin 3 of the "D" connector is used to reset controller time.

From the main menu press: 4 - T. B. COOR., then press: 2 - TBC PARMs, then enter: 04:00 under the LOAD function.

Connect the TR-3 / TR-4 relay common wire to logic ground and the normally open wire to pin 3 of the "D" connector which is the SYSTEM/TOD RESYNC function.

Set the switches on the TR-3 / TR-4 for a time reset at 4:00AM, Everyday (EDY) per the TR-3 / TR-4 programming instructions.

NOTE: The controller must have something active in the TBC or the real time clock will stop.

DISCLAIMER:

The information contained in this application note is accurate to the best of our knowledge. It is the responsibility of the end user to determine the method of resetting the time of day on the exact model and firmware version of the controller being used.